**Adaptor M12 male / M12 female A-cod.**

4-pol., Bridge 1-2, for Diagnose Cube67

Adapter
Male - female
M12 – M12, 4-pole (circuit diagram)
Bridge PIN 1 + 2

Link til produkt

**Illustrasjon**












Produktet kan avvike fra bildet

| | |
|---|---|
| **Side 1** | |
| Mounting method | inserted, screwed |
| Degree of protection (EN IEC 60529) | IP67 |
| **Side 2** | |
| Mounting method | inserted, screwed |
| Degree of protection (EN IEC 60529) | IP67 |
| **Handelsinformasjon** | |
| ECLASS-6.0 | 27143423 |
| ECLASS-6.1 | 27260702 |
| ECLASS-7.0 | 27440102 |
| ECLASS-8.0 | 27440102 |
| ECLASS-9.0 | 27440106 |
| ECLASS-10.1 | 27440102 |
| ECLASS-11.1 | 27440102 |
| ECLASS-12.0 | 27440106 |
| ETIM-5.0 | EC001855 |
| GTIN | 4048879144742 |
| Pakkestørrelse | 1 |
| Tolltariffnummer | 85366990 |
| **Electrical data \| Supply** | |
| Operating voltage AC max. | 250 V |
| Operating voltage DC max. | 250 V |
| Operating voltage AC (UL-listed) | 30 V |
| Operating voltage DC (UL-listed) | 30 V |
| Current operating per contact max. | 4 A |
| **Installation \| Connection** | |
| Tightening torque | 0,6 Nm |
| Mounting set | M12 x 1 |
| **Device protection \| Electrical** | |
| Additional condition protection degree | inserted, screwed |
| Pollution Degree | 3 |
| Rated insulation voltage | 800 V |

| | |
|---|---|
| Rated surge voltage | 2,5 kV |
| Material group (IEC 60664-1) | I |
| **Mechanical data \| Material data** | |
| Coating locking | Nickeled |
| Material housing | PUR |
| Locking material | Zinc die-casting |
| **Mechanical data \| Mounting data** | |
| Mounting method | inserted, screwed, Shaking protection |
| **Environmental characteristics \| Climatic** | |
| Operating temperature min. | -25 °C |
| Operating temperature max. | 85 °C |
| **Important installation notes** | |
| Note on strain relief | Protect the connectors by suitable measures from mechanical loads, e.g. by the usage of cable ties. |
| Note on bending radius | **Attention:** Observe the permissible bending radii when laying cables, as the IP protection class can be endangered by excessive bending forces. |